

### **SOLICITATION ADDENDUM NO. 1**

Project Title	Date Prepared	Project No.
SJCCD Maritime Expansion Fire Training Center	November 26, 2019	CSP 20-12

Respondent for this solicitation shall acknowledge receipt of this addendum. This document shall be submitted with all other required documents.

### **QUESTIONS & ANSWERS:**

• All submitted questions have been answered under the Questions tab in the e-bidding website (<a href="https://sanjac.ionwave.net">https://sanjac.ionwave.net</a>).

# **UPDATES:**

The following changes have been made to drawings:

- 1. Sheet M2.01- 1ST DECK MECHANICAL PLAN AREA "A1"
  - a. Replace this sheet in its entirely.
  - b. Relocate ACU-1B and associated refrigerant piping inside Mezzanine Deck 200.
  - c. Included a section view for relocation of ACU-1B for better visualization.
  - d. Included Mechanical Symbol Schedule for better understanding of symbols used throughout the project.
  - e. LTY preliminary disclaimer was removed.
  - f. Control devices were relocated to the exterior wall.
  - 2. Sheet E1.01 1ST DECK COMPOSITE ELECTRICAL PLAN
  - Removed new service to SJC building and provide new electrical feed from existing Maritime building.
  - b. Redirected power for the new Fire Trainer from the new SJC building to an emergency generator fed panel 'HD' within the Maritime building.
  - c. Relocated existing electrical boxes at the drive way.
- 2. Sheet E2.01 1ST DECK ELECTRICAL POWER PLAN AREA "A1"
  - Relocated disconnect switch for ACU-1B.
  - b. Added new transformer 'XQ' to second floor of building.
  - c. Removed underground conduit route from SJC building to new Fire Trainer.
  - 9. Sheet E2.02 1ST DECK ELECTRICAL LIGHITNG PLAN AREA "A1"
  - a. Removed wallpacks shown on first floor plan.
  - b. Relocated switch on second floor next to electrical panel.
  - c. Reformatted the control layout of fixtures on the first and second floor storage rooms.
  - d. Altered fixtures types in lighting schedule.
  - e. Altered descriptions of fixture L1, L1E, L2 and L2E.



### 3. Sheet E4.00 – ELECTRICAL SINGLE LINE DIAGRAM

- a. Provide new existing and revised single line diagram to show all new connections made to the existing Maritime Center.
- b. Provided note for existing distribution panel 'DM' for 'Contractor to provide new circuit breaker and wire for new circuit'.
- c. Added new transformer 'XP' and circuit breaker to existing Maritime center for the new Fire Trainer.
- d. Re-fed the new SJC building from the existing distribution panel 'DM'.
- e. Added new transformer inside SJC building
- f. Load analysis revised for SJC building.
- 4. Sheet E5.00 SPECIFICATIONS, LEGEND AND DETAILS
  - a. Provided new transformer detail.
- 5. Sheet E5.01 ELECTRICAL LIGHITNG DETAILS
  - a. Revised detail #1, removing the fixture GTD controller and adding new notes below details.

# **Re-issued Sheets**

Sheet P1.01 - 1ST DECK COMPOSITE PLUMBING PLAN

Sheet P3.00 - PLUMBING DETAILS AND SCHEDULES

Sheet M2.01 - 1ST DECK MECHANICAL PLAN AREA "A1"

Sheet E1.01 - 1ST DECK COMPOSITE ELECTRICAL PLAN

Sheet E2.01 - 1ST DECK ELECTRICAL POWER PLAN AREA "A1"

Sheet E2.02 - 1ST DECK ELECTRICAL LIGHITNG PLAN AREA "A1"

Sheet E4.00 - ELECTRICAL SINGLE LINE DIAGRAM

Sheet E5.00 - SPECIFICATIONS, LEGEND AND DETAILS

Sheet E5.01 - ELECTRICAL LIGHITNG DETAILS

### **NEW ISSUED SHEETS**

Sheet E4.01 - ELECTRICAL LIGHITNG PANEL SCHEDULES

### **ATTACHMENTS:**

# **DRAWINGS**

Sheet P1.01 – 1ST DECK COMPOSITE PLUMBING PLAN

Sheet P3.00 - PLUMBING DETAILS AND SCHEDULES

Sheet M2.01 - 1ST DECK MECHANICAL PLAN AREA "A1"

Sheet E1.01 - 1ST DECK COMPOSITE ELECTRICAL PLAN

Sheet P1.01 - 1ST DECK COMPOSITE PLUMBING PLAN

Sheet P3.00 - PLUMBING DETAILS AND SCHEDULES

Sheet M2.01 - 1ST DECK MECHANICAL PLAN AREA "A1"

Sheet E1.01 - 1ST DECK COMPOSITE ELECTRICAL PLAN

Sheet E2.01 - 1ST DECK ELECTRICAL POWER PLAN AREA "A1"

Sheet E2.02 - 1ST DECK ELECTRICAL LIGHITNG PLAN AREA "A1"

Sheet E4.00 – ELECTRICAL SINGLE LINE DIAGRAM

Sheet E5.00 - SPECIFICATIONS, LEGEND AND DETAILS

Sheet E5.01 - ELECTRICAL LIGHITNG DETAILS

Sheet E4.01 – ELECTRICAL LIGHITNG PANEL SCHEDULES



# Pre-Bid Meeting Sign-In Sheet

Acknowledgement of Addendum No. 1 by the undersigned:			
Company Name (Bidder / Offeror):	Date:		
Signed by:			
Name (Type or Print):	Title:		